

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-1076:146 Page 1 of 1

CATEGORY: Control Unit (Non High Rise)

LISTEE: Kidde-Fenwal, Inc., 400 Main Street, Ashland, MA 01721
Contact: Terrill Garland (508) 881-2000

DESIGN: Model PEGASYS and PEGASYS ML fire alarm control panels. Power limited. Automatic, manual, coded, noncoded, local, auxiliary, remote station, *central station, waterflow and sprinkler supervisory service. Also suitable for releasing device. Refer to listee's data sheet for additional detailed system description and operational considerations. System components:

76-100008-501	Central Control Module
76-100007-001	I/O Motherboard
76-100005-001	RX/TX Module
76-100004-001	Relay Module
76-100003-001	Signal Audible Module
76-100002-001	City Tie Module
76-100009-001	Power Supply Controller
76-100001-001	Release Module
76-100017-001	Multi-loop Motherboard
76-100009-010	Power Supply Module
76-100008-600*	ML Central Control Module
76-100036-500*	Network Interface Card

RATING: Primary: 120/240 VAC, Standby: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as fire alarm control unit for use with listee's separately listed electrically and functionally compatible initiating and indicating devices. This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

NOTE: For Fire Alarm Verification Feature (delay of fire alarm), the maximum Retard/Reset/Restart period must be adjusted to 30 seconds or less.

*Corrected 08-02-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 12, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**